

தடையின்மைச்சான்று

திருப்பெரும்புதூர் தீயணைப்பு மீட்புப் பணிகள் நிலையம்

ந.க.எண்: 36/V/2025

நாள்: 06.02.2026

பொருள்: தீயணைப்பு மீட்புப்பணித்துறை - திருப்பெரும்புதூர் தீயணைப்பு மீட்புப் பணிகள் நிலையம்-பள்ளிக்கூடம் நிறுவிட/அங்கீகாரம் வழங்கிட தடையின்மைச் சான்று வழங்குதல் குறித்து.

பார்வை: 1. அரசு ஆணை எண்.122 பள்ளி கால்வி (2) துறை, நாள்:14.09.2004.

அரசு ஆணை எண். 123 பள்ளி கல்வி (2) துறை, நாள்: 14.09.2004.

3. P.S SENIOR SECONDARY SCHOOL (ORAGADAM)

என்பவரிடமிருந்து பெறப்பட்ட விண்ணப்பம். நாள்: 0401.2026.

பார்வையில் காணும் அரசாணை மற்றும் விண்ணப்பத்தின்படி S.P Kovil To Sriperumbudur Road, Mathur Village, Sriperumbudur Taluk, Kanchipuram District என்ற முகவரியில் நிறுவப்பட்டுள்ள M/s: P.S. SENIOR SECONDARY SCHOOL, (ORAGADAM) என்ற இடத்தினை 06.02.2026 அன்று திருப்பெரும்புதூர் நிலைய அலுவலர் திரு.வ.வடிவேலு அவர்களால் ஆய்வு செய்யப்பட்டது. இவ்விடத்தில் பள்ளிக்கூடம் நிறுவிட/அங்கீகாரம் வழங்கிட கீழ்காணும் நிபந்தனைகளுக்குட்பட்டு தீயணைப்பு மீட்புப்பணி நோக்கிலிருந்து யாதொரு தடையுமில்லை எனச் சான்றிடலாகிறது.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
 - b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students

பெறுநர்:

M/s: P.S. SENIOR SECONDARY SCHOOL, (ORAGADAM)

S.P Kovil To Sriperumbudur Road,

Mathur Village, Sriperumbudur Taluk, Kancheepuram District.

2. Jan 6/2/26
நிலைய அலுவலர்
தீயணைப்பு-மீட்புப்பணி நிலையம்
திருப்பெரும்புதூர்-602 105